

Rev: 5.31.2016

INDOOR ENVIRONMENTAL QUALITY (IEQ)

MOLD PREVENTION

IEQ CREDIT 10

(SCHOOLS - 1 point)

Intent

To reduce the potential presence of mold in

SCHOOLS

through preventive design and construction. measures.

Requirements

SCHOOLS

Project teams must achieve the following credits:

IEQ Credit 3.1: Construction Indoor Air Quality Management Plan—During Construction

IEQ Credit 7.1: Thermal Comfort—Compliance

IEQ Credit 7.2: Thermal Comfort—Verification

Provide heating, ventilating and air conditioning (HVAC) systems and controls designed to limit space relative humidity to 60% or less during all load conditions, both occupied and unoccupied.

Develop and implement on an ongoing basis an IAQ management program for buildings based on the U.S. Environmental Protection Agency (EPA) document, Building Air Quality: A Guide for Building Owners and Facility Managers, EPA reference number 402-F-91-102, December 1991.

LEED® is a registered trademark and property of the U.S. Green Building Council, and may not be used without their written consent and permission. For more information visit www.usgbc.org. Copyright © 2010 U.S. Green Building Council. All Rights Reserved.